



**Butoane simple**

$I_e$ (AC 1, 230 V) <b>6 A</b>	$I_e$ (AC 15, 230 V) <b>3 A</b>	$I_e$ (DC 13, 250 V) <b>0,27 A</b>	$U_i$ <b>660 V</b>	$[mm^2]$ <b>0,5-2,5</b>	$\times 10^6$	$F_{on}$ <b>max. 20 N</b>	$T_a$ <b>-25..+40°C</b>	
-----------------------------------	------------------------------------	---------------------------------------	-----------------------	----------------------------	---------------	------------------------------	----------------------------	--




TRACON		IP 65	IP65	NC	NO
<b>NYG3-BK</b>				1 x NO	
<b>NYG3-G</b>				1 x NO	
<b>NYG3-W</b>				1 x NO	
<b>NYG3-Y</b>				1 x NO	
<b>NYG3-B</b>				1 x NO	
<b>NYG3-R</b>				1 x NC	
<b>RELEVANT STANDARD EN 60947-1</b>		<b>RELEVANT STANDARD EN 60947-5-1</b>			




**Comutatoare simple**

$I_e$ (AC 1, 230 V) <b>6 A</b>	$I_e$ (AC 15, 230 V) <b>3 A</b>	$I_e$ (DC 13, 250 V) <b>0,27 A</b>	$U_i$ <b>660 V</b>	$[mm^2]$ <b>0,5-2,5</b>	$\times 10^6$	$F_{on}$ <b>max. 20 N</b>	$F_{off}$ <b>max. 15 N</b>	$T_a$ <b>-25..+40°C</b>	
-----------------------------------	------------------------------------	---------------------------------------	-----------------------	----------------------------	---------------	------------------------------	-------------------------------	----------------------------	--




TRACON		IP 65	IP65	NC	NO
<b>NYK3-BK</b>				1 x NO	
<b>NYK3-G</b>				1 x NO	
<b>NYK3-W</b>				1 x NO	
<b>NYK3-Y</b>				1 x NO	
<b>NYK3-B</b>				1 x NO	
<b>NYK3-R</b>				1 x NC	
<b>RELEVANT STANDARD EN 60947-1</b>		<b>RELEVANT STANDARD EN 60947-5-1</b>			



**Butoane în relief**

$I_e$ (AC 1, 230 V) <b>6 A</b>	$I_e$ (AC 15, 230 V) <b>3 A</b>	$I_e$ (DC 13, 250 V) <b>0,27 A</b>	$U_i$ <b>660 V</b>	$[mm^2]$ <b>0,5-2,5</b>	$\times 10^6$	$F_{on}$ <b>max. 20 N</b>	$T_a$ <b>-25..+40°C</b>	
-----------------------------------	------------------------------------	---------------------------------------	-----------------------	----------------------------	---------------	------------------------------	----------------------------	--



TRACON		IP 42	IP42	NC	NO
<b>NYG3-HBK</b>				1 x NO	
<b>NYG3-HG</b>				1 x NO	
<b>NYG3-HW</b>				1 x NO	
<b>NYG3-HY</b>				1 x NO	
<b>NYG3-HB</b>				1 x NO	
<b>NYG3-HR</b>				1 x NC	
<b>RELEVANT STANDARD EN 60947-1</b>		<b>RELEVANT STANDARD EN 60947-5-1</b>			

