

MTX 160 / MTXE 160 - MCCB'S UP TO 160 A

MTX 160 - MCCB'S - N TYPE - 36 KA



Code	Rated current	Pack Carton
No. of pole	is: 3P	
GW D7 931	10 A	1
GW D7 932	16 A	1
GW D7 933	20 A	1
GW D7 934	25 A	1
No. of pole	is: 4P	
GW D7 936	10 A	1
GW D7 937	16 A	1
GW D7 938	20 A	1
GW D7 939	25 A	1

GW D7 938

ACCESSORIES SUPPLIED: supplied with front terminals (F).

MTX 160 - MCCB'S FOR GENERATOR PROTECTION - N TYPE - 36 KA



GW D7 094

Code	Rated current	Pack Carton
No. of pol	es: 3P	
GW D7 081	25 A	1
GW D7 082	40 A	1
GW D7 083	63 A	1
GW D7 084	80 A	1
GW D7 085	100 A	1
GW D7 086	125 A	1
GW D7 087	160 A	1
No. of pol	es: 4P	
GW D7 091	25 A	1
GW D7 092	40 A	1
GW D7 093	63 A	1
GW D7 094	80 A	1
GW D7 095	100 A	1
GW D7 096	125 A	1
GW D7 097	160 A	1

NOTES: for mounting on EN 50022 DIN rail, choose the fixing bracket GWD8261.

The space taken up on the EN 50022 DIN rail is approximately 5 modules for the 3P versions and 7 modules for the 4P versions.

ACCESSORIES SUPPLIED: supplied with front terminals (F).

ΜΤΧ



COMPLETE AND SPECIFIC ACCESSORIES



The MTX range is full of common accessories that streamline the installation and allow to reach additional functions such as remote opening, operating status by remote, engine control etc.

SOLUTIONS FOR AN INTEGRATED SYSTEM



The MTX range integrates perfectly with 47 CVX and 46 distribution boards thanks to the installation kit on plate and on DIN rail.

IDEAL RANGE FOR EVERY NEED



The moulded case circuit breakers MTX range is made up of circuit breakers with thermo-magnetic release, circuit breakers with magnetic release only, circuit breakers with electronic release, switch disconnectors, add-on residual current circuit breaker.

MCCB WITH THERMOMAGNETIC AND MAGNETIC RELEASES

MTX 160C

	THERMOMAGNETIC RELEASES - TM1													
	L1 - L2 - L3 (Ith)*	(A)	16 ⁽¹⁾	20 ⁽¹⁾	25 ⁽²⁾	32	40	50	63	80	100	125	160	
	Neutral (Ith)*	(A)	16	20	25	32	40	50	63	80	100	125	160	
MTX 160c														
Circuit breaker for power distribution	l ₃ **	(A)	630	630	630	630	630	630	630	800	1000	1250	1600	
(1) Breaking capacity B only (2) Breaking	capacity B and C only													

The thermal element of the thermomagnetic releases has an adjustable threshold with range (0.7 - 1) x lth.

This adjustment is done by positioning the selector at the minimum value MIN (0.7 XIth), the average value MED (0.85 XIth) or the maximum value MAX (1xIth). Placing the selector in an intermediate position (for example between MIN and MED) is not possible to know with certainty the value of the corresponding thermal trip.

The adjusted current value obtained should be considered rated at 40°C

Neutral 100% protected

* "Ith" indicates the calibration current of the relay to protect the phases and neutral ** Magnetic tripping current with fixed threshold

MTX 160

		TH	IERMOMAGNETIC RELE	ASES - TM1		
	L1 - L2 - L3 (Ith)*	(A)	10	16	20	25
	Neutral (Ith)*	(A)	10	16	20	25
MTX 160						
Circuit breaker for power distribution	l ₃ **	(A)	100	500	500	500

The thermal element of the thermomagnetic releases has an adjustable threshold with range $(0.7 - 1) \times 1$ th.

This adjustment is done by positioning the selector at the minimum value MIN (0.7 XIth), the average value MED (0.85 XIth) or the maximum value MAX (1xIth).

Placing the selector in an intermediate position (for example between MIN and MED) is not possible to know with certainty the value of the corresponding thermal trip. The adjusted current value obtained should be considered rated at 40°C

Neutral 100% protected

* "Ith" indicates the calibration current of the relay to protect the phases and neutral ** Magnetic tripping current with fixed threshold

MTX 160

	THERM	IOMAGNETI	C RELEASES	FOR GENERA	TOR PROTEC	TION - TMG			
	L1 - L2 - L3 (Ith)*	(A)	25	40	63	80	100	125	160
	Neutral (Ith)*	(A)	25	40	63	80	100	125	160
MTX 160									
Circuit breaker for generator protection	l ₃ ** = 3xin	(A)	160	200	200	240	300	375	480
The thermal element of the the	ermomagnetic releases ha	s an adjustable	e threshold with	range (0.7 - 1) x I	th.				

This adjustment is done by positioning the selector at the minimum value MIN (0.7 XIth), the average value MED (0.85 XIth) or the maximum value MAX (1xIth). Placing the selector in an intermediate position (for example between MIN and MED) is not possible to know with certainty the value of the corresponding thermal trip.

Neutral 100% protected

* "Ith" indicates the calibration current of the relay to protect the phases and neutral ** Magnetic tripping current with fixed threshold



MTX 160

MAGNETIC RELEASES FOR MOTOR PROTECTION - M																		
	L1 - L2 - L3 (Ith)*	(A)	1 ⁽¹⁾	1.6 ⁽¹⁾	2 ⁽¹⁾	2.5 (1)	3.2 ⁽¹⁾	4 ⁽¹⁾	5 ⁽¹⁾	6.5 ⁽¹⁾	8.5 ⁽¹⁾	11 ⁽¹⁾	12.5 ⁽¹⁾	20 ⁽²⁾	32 ⁽²⁾	52 ⁽²⁾	80 ⁽²⁾	100 (2)
MTX 160																		
Circuit breaker for motor protection	l ₃ **	(A)	13	21	26	33	42	52	65	84	110	145	163	240	384	624	960	1200
(1) I3 = 13xIth; (2) I3 = (6 ÷ 12) Ith	·																	
The adjusted current value obtained should be considered rated at 40°C																		
* "Ith" indicates the calibration current of	* "Ith" indicates the calibration current of the relay to protect the phases and neutral ** Magnetic tripping current																	

MTX 250

THERMOMAGNETIC RELEASES - TM1													
	L1 - L2 - L3 (Ith)*	(A)	63	80	100	125	160	200	250				
	Neutral (Ith)*	(A)	63	80	100	125	160	200	250				
MTX 250													
Circuit breaker for power distribution	l₃** = 10xin	(A)	630	800	1000	1250	1600	2000	2500				
distribution The thermal element of the t	hermomagnetic releases ha	es an adiustable	threshold with	range (0.7 - 1) x l	th	1250	1000	2000					

This adjustment is done by positioning the selector at the minimum value MIN (0.7 XIth), the average value MED (0.85 XIth) or the maximum value MAX (1xIth). Placing the selector in an intermediate position (for example between MIN and MED) is not possible to know with certainty the value of the corresponding thermal trip.

The adjusted current value obtained should be considered rated at 40°C

Neutral 100% protected

* "Ith" indicates the calibration current of the relay to protect the phases and neutral ** Magnetic tripping current with fixed threshold

MTX 250

THERMOMAGNETIC RELEASES FOR GENERATOR PROTECTION - TMG													
	L1 - L2 - L3 (Ith)*	(A)	(A) 63	80	100	125	160	200	250				
	Neutral (Ith)*	(A)	63	80	100	125	160	200	250				
MTX 250													
Circuit breakers for generator protection	l ₃ ** = 3xIn	(A)	400	400	400	400	480	600	750				
The thermal element of the the	ermomagnetic releases ha	s an adjustable	e threshold with	range (0.7 - 1) x	lth.								

This adjustment is done by positioning the selector at the minimum value MIN (0.7 XIth), the average value MED (0.85 XIth) or the maximum value MAX (1xIth). Placing the selector in an intermediate position (for example between MIN and MED) is not possible to know with certainty the value of the corresponding thermal trip.

The adjusted current value obtained should be considered rated at 40°C

Neutral 100% protected

* "Ith" indicates the calibration current of the relay to protect the phases and neutral ** Magnetic tripping current with fixed threshold

MTX 250

MAGNETIC RELEASES FOR MOTOR PROTECTION - M												
	L1 - L2 - L3 (Ith)*	(A)	100 (1)	125 (1)	160 (1)	200 (1)						
MTX 250	· · · · · ·		·	·								
Circuit breaker for motor protection	l ₃ **	(A)	1200	1500	1920	2400						
⁽¹⁾ I3 = (6 - 12) Ith												
The adjusted current value of	otained should be considered	rated at 40°C										
* "Ith" indicatos the salibration surront	of the velocity on protect the phones and	noutral ** Magnetic tripping	current									

"Ith" indicates the calibration current of the relay to protect the phases and neutral Magnetic tripping current