

# Auxiliary devices for KMI and KTI AC contactors

## PKI contact devices PVI time-delay devices

PKI contact devices are intended for expanding the possibilities of contactor application within technology project automation systems. Pneumatic PVI time-delay devices provide for delaying the closing or opening of auxiliary circuits lasting from 0,1 to 180 s. They are used in combination with KMI and KTI series of contactors.

Correspond to the requirements EN 60947-1, EN 60947-4-1, EN 60947-5-1

### Range

	Description	No. and type of contacts	Qty, pcs in package	Product ID
			in shipping box	
	PKI-04 auxiliary contacts 4 NC IEK	4 NC	1	KPK10-04
	PKI-11 auxiliary contacts 1 NO + 1 NC IEK	1 NO + 1 NC	1	KPK10-11
	PKI-20 auxiliary contacts 2 NO IEK	2 NO	1	KPK10-20
	PKI-22 auxiliary contacts 2 NO + 2 NC IEK	2 NO + 2 NC	1	KPK10-22
	PKI-40 auxiliary contacts 4 NO IEK	4 NO	1	KPK10-40
	PVI-11 ON delay 0.1-30 s, 1 NO + 1 NC	1 NO + 1 NC	10	KPV10-11-1
	PVI-12 ON delay 10-180 s, 1 NO + 1 NC	1 NO + 1 NC	10	KPV10-11-2
	PVI-13 ON delay 0.1-3 s, 1 NO + 1 NC	1 NO + 1 NC	10	KPV10-11-3
	PVI-21 OFF delay 0.1-30 s, 1 NO + 1 NC	1 NO + 1 NC	10	KPV20-11-1
	PVI-22 OFF delay 10-180 s, 1 NO + 1 NC	1 NO + 1 NC	10	KPV20-11-2
	PVI-23 OFF delay 0.1-3 s, 1 NO + 1 NC	1 NO + 1 NC	10	KPV20-11-3